

**Beaumont Fire-Rescue Services**

**PERFORMANCE BENCHMARKS**

**404.02C**

**Pressure Control Device**

**Discipline:** D/O  
**Effective:** 6/5/2002  
**Revised:** 10/5/2009  
**Replaces:** Driver Benchmark 209

*Anne Huff, Fire Chief*

**I. Objective**

The Driver/Operator, given a fire department pumper, shall demonstrate the operation of the pump pressure control device—relief valve or pressure control governor.

**II. Instructions – Procedures for Achieving the Objective**

Given a fire department pumper, you shall demonstrate the operation of the pump pressure control device—relief valve or pressure control governor (as required by the field examiner). The skill will end when you state to me that you have completed all of the identified steps. Do you understand these instructions?

**III. Examiner's Note**

The Driver/Operator will not be allowed to review the performance steps at the time of testing

**IV. Preparation & Equipment**

A. Fire department pumper with pressure control device.

**V. Reference Sources**

- A. IFSTA, Pumping Apparatus Driver/Operator Handbook, 2<sup>nd</sup> Edition
- B. TCFP, Performance Standard, Section 705-2.02
- C. NFPA 1002 3-1.1, 3-2.1

# 404.02C – Pressure Control Device

**Discipline: D/O**

Name:	Officer #:
Evaluator:	Officer #:
Date:	Location:

**If the Driver/Operator:**

**(No partial points given)**

- a) Checks that all lines are flowing at the desired rate ..... 2.0 \_\_\_\_\_
- b) Turns on the governor knob in the set position ..... 2.0 \_\_\_\_\_
- c) Turns the throttle control to the designated operating pressure ..... 2.0 \_\_\_\_\_
- d) Places the governor knob in the run position ..... 2.0 \_\_\_\_\_

Points Possible	Passing Score	Attempt	Performance Rating (Points)	PASS	FAIL
<b>8</b>	<b>6</b>	First			
		Second			
		Third			